

## Release N

- ESPS changes scheduled for deployment May 2025
- NPDR & wind dispatchability improvements scheduled for September 2025
- Factory Acceptance Testing is complete
  
- 2 Defects from Known Issues Report planned to be fixed
  - 271634 Incorrect application of PBOA in Imbalance Pricing for Pump Storage Units
  - 318254 Incorrect Loss factor for Net Capacity Quantity (QCNET) Calculation

Ref	Change Request	Business Area
CR 313	Update to start up payment conditions in CSB	Settlement
CR 319	Third party software for ISEM Release N incl SABLE	IT
CR 318	REPT_042 and System Imbalance (change to account for NPDR)	SDP
SDPCR-01	Operation of non-priority dispatch of renewables	SDP
SDPCR-02	Energy Storage Power Station (ESPS) integration	SDP



## Future Releases

- Release O (SDP Tranche 2)
- Scheduled for deployment November 2025
  - SDP-03 Fast Frequency Response (FFR)
  - SDP-05 Reserve services scheduling and dispatch
  - SDP-06 Synchronous condenser scheduling and dispatch
- Design workshops & discussions with Ras ongoing
- Forecast go-live November 2025



# Future Releases:

- SEMO Market Systems Forward Release Plan published 6<sup>th</sup> June 2024

MMS Release Reference	Release Type	Target Deployment
MMS Release M	Scheduled	July 2024
MMS Release N	Scheduled	April 2025
MMS Release O	Scheduled	October 2025



## Single Electricity Market



### COPYRIGHT NOTICE

All rights reserved. This entire publication is subject to the laws of copyright. This publication may not be reproduced or transmitted in any form or by any means, electronic or manual, including photocopying without the prior written permission of EirGrid plc and SONI Limited.

### DOCUMENT DISCLAIMER

Every care and precaution is taken to ensure the accuracy of the information provided herein but such information is provided without warranties express, implied or otherwise howsoever arising and EirGrid plc and SONI Limited to the fullest extent permitted by law shall not be liable for any inaccuracies, errors, omissions or misleading information contained herein.

