

Scheduling & Dispatch

September 2019



COPYRIGHT NOTICE

All rights reserved. This entire publication is subject to the laws of copyright. This publication is confidential and sole property of EirGrid plc and SONI Limited. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or manual, including photocopying without the prior written permission of EirGrid plc and SONI Limited. © SONI Limited / EirGrid Plc 2019


DOCUMENT DISCLAIMER

This manual is intended as a guide only. Whilst every effort is made to provide information that is useful, and care is taken in the preparation of the information, EirGrid plc and SONI limited give no warranties or representations, expressed or implied, of any kind with respect to the contents of this document, including, without limitation, its quality, accuracy and completeness. EirGrid plc and SONI limited hereby exclude, to the fullest extent permitted by law, all and any liability for any loss or damage howsoever arising from the use of this document or any reliance on the information it contains. Use of this document and the information it contains is at the user's sole risk.

Agenda

1. Introduction
2. Scheduling Process
3. Dispatch Process
4. WSAT


Control Centre



From SEM to I-SEM


	SEM	I-SEM
Gate closure	EA2 WD1 > 10 hr notice	Half-hourly 1 hr before real-time 08:40 11:54 18:10 ICRP updates
Unit Prices	Single curve Bidding Code of Practice 'BCoP'	Dual curve - Inc/Dec Simple and complex data Partly 'BCoP'd
Start point for scheduling	Market prices (fixed), Interconnector nominations Current dispatch	Market Physical Notifications (PNs), Varying prices (from PNs), Interconnector schedules Current dispatch
Cost optimisation objective	Minimise production cost	Minimise cost of deviating from PNs*
Scheduling process	Day Ahead, Inday 1, Inday 2 & Inday 3, and ad hoc as required	Continuous (100+) Economic dispatch (every 5 mins)
Energy Balance	Implicitly balanced	Market participants are balance responsible
Price	Ex-post unconstrained price	Real Time Imbalance Price

System Overview for Scheduling & Dispatch




Scheduling


Scheduling Run Sequence




The Optimisation




Load Forecasting




Load Prediction & Blending




Load shapes




Wind Forecast



Wind Forecast Blending





Actual Wind v's Forecast Wind



Commercial Offer Data (COD)


The following Bid Offer Data is used in each run type for scheduling decisions:

Scheduling/Dispatch Run	Source of Commercial Data		
	Primary	Back-Up 1	Back-Up 2
LTS – Long Term Schedule	Complex	Default	N/A
RTC – Real-Time Commitment	Complex	Default	N/A
RTD – Real-Time Dispatch	Simple	Complex	Default



Cost Curve

Production of Composite Cost Curves:




Technical Offer Data (TOD)

As detailed in Appendix I of Trading and Settlement Code, largely unchanged from SEM including:

- Block load
- Load up rate
- Soak up time
- Minimum Stable Generation level
- Ramp up rate
- Dwell up time
- Ramp down rate
- Dwell down time
- Maximum Availability
- Minimum On Times, Minimum Off Time
- Cooling Boundaries
- Forecast Profiles (Availability, Minimum Output, Minimum Stable Generation)
- Short-term Maximisation Capacity and Time
- Synchronous Start up times for three different heat states
- De-load rate

Reserve

Primary Operating Reserve (POR) Curve



GMN	140
GMX	400
R1	15
R2	25
β	60
$\Delta 1$	25

Primary Operating Reserve (POR) – 5 to 15 Seconds
 Secondary Operating Reserve (SOR) – 15 to 90 Seconds


Required to carry
 75% Largest Infeed

Tertiary Operating Reserve 1 (TOR1) – 90 to 5 Minutes
 Tertiary Operating Reserve 2 (TOR2) – 5 to 20 Minutes

Required to carry
 100% Largest Infeed

Interconnector Reference Program

Production of Interconnector Reference Programme:




Example PN's

PNs	Availability Max / Min	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00
Unit A	400 / 200	400	400	400	400	400	400	400	400	400	400	400	400	400	400
Unit B	400 / 200	300	350	400	400	400	400	400	400	400	400	400	400	300	200
Unit C	400 / 200	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Unit D	300 / 100	100	200	250	250	300	250	200	200	200	250	300	300	250	200
Unit E	300 / 100	100	200	200	200	200	200	200	200	200	250	300	200	100	100
Unit F	100 / 20	0	0	0	0	0	0	0	0	0	100	100	50	0	0
Unit G	100 / 20	0	0	0	0	0	0	0	0	0	0	50	0	0	0
Unit H	50 / 10	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total PN		900	1150	1250	1250	1300	1250	1200	1200	1200	1400	1550	1350	1050	900
Demand		900	1150	1250	1250	1300	1250	1200	1200	1200	1400	1550	1350	1050	900

Snapshot of PNs submitted for 08:00 to 21:00

For illustration purposes this data is presented at hourly resolution.

Example PN's



System Security

Reserve (Frequency)	Thermal	Voltage	Dynamic Stability	Short Circuit
All Island OR Requirement	North-South Tie-Line Limit	NI North West Generation	Inertia	Operational Switching
NI/ROI Min OR Requirement	Cork Generation Export Limit	Dublin Generation	RoCoF	
NI/ROI Replacement Reserve ("GTs")		South West Must Run	SNSP	
NI/ROI Negative Ramping Reserve		400kV network Generation	NI 3 Units Must Run	
Ramping (1hr 3hr 8hr)			ROI 5 Units Must Run	


LTS Example

PNs	Availability Max / Min	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00
Unit A	400 / 200	400	400	400	400	400	400	400	400	400	400	400	400	400	400
Unit B	400 / 200	300	350	400	400	400	400	400	400	400	400	400	400	300	200
Unit C	400 / 200	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Unit D	300 / 100	100	200	250	250	300	250	200	200	200	250	300	300	250	200
Unit E	300 / 100	100	200	200	200	200	200	200	200	200	250	300	200	100	100
Unit F	100 / 20	0	0	0	0	0	0	0	0	0	100	100	50	0	0
Unit G	100 / 20	0	0	0	0	0	0	0	0	0	0	50	0	0	0
Unit H	50 / 10	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total PN		900	1150	1250	1250	1300	1250	1200	1200	1200	1400	1550	1350	1050	900
Demand		900	1150	1250	1250	1300	1250	1200	1200	1200	1400	1550	1350	1050	900

LTS Run

Schedule	Availability Max / Min	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00
Unit A	400 / 200	370	370	370	370	370	370	370	370	370	370	370	370	370	370
Unit B	400 / 200	330	350	370	370	370	370	370	370	370	370	370	370	280	230
Unit C	400 / 200	0	200	200	200	200	200	200	200	200	200	200	200	200	0
Unit D	300 / 100	100	130	210	210	260	210	160	160	160	250	270	270	100	200
Unit E	300 / 100	100	100	100	100	100	100	100	100	100	190	270	120	100	100
Unit F	100 / 20	0	0	0	0	0	0	0	0	0	20	20	20	0	0
Unit G	100 / 20	0	0	0	0	0	0	0	0	0	0	50	0	0	0
Unit H	50 / 10	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Sch		900	1150	1250	1250	1300	1250	1200	1200	1200	1400	1550	1350	1050	900
Demand		900	1150	1250	1250	1300	1250	1200	1200	1200	1400	1550	1350	1050	900

LTS Example Cont'd




Forecast Availability v Declared

	Declared Max [MW]	Forecast Avail Max [MW]
Unit A	400	425
Unit B	400	408
Unit C	400	435
Unit D	300	310
Unit E	300	308
Unit F	100	105
Unit G	100	110
Unit H	50	59
	2050	2160

110MW Difference

LTS Availability



LTS uses forecast availability, when it comes to real time the declared availability can be much lower, this leaves the real time schedules short, causing expensive short notice plant to be called, affecting imbalance pricing.

Dispatch


Dispatch

INC/DEC Merit Order

Unit	Current DI	Min Gen	Max Gen	Actual Output	PN	Price € MWh
A	396	150	431	398	431	20
B	335	130	390	332	380	25
C	375	100	400	374	400	26
D	60	20	120	60	100	30

OFFLINE Merit Order

Unit	PN	Min Gen	Max Gen	Cost € MWh	Notification Time [hr]
E	0	10	55	80	0.17
F	0	10	50	120	0.33
G	0	20	90	125	0.33
H	0	60	250	20,000	6



Wind Dispatch

Reason for Wind dispatch

- **Curtailment** required for high wind output at low loads and minimum generation.
- **Constraint** required if there is insufficient transmission capacity to transport wind generation from weakly connected regions.

Curtailment/Constraint setpoints are issued to windfarms via the wind dispatch tool in the EMS

Active Power Control Status

Transfers control of active power setpoint to TSO control centre

Available MW


Calculated value provided by the wind farm

Wind MW

Present wind farm output

WF Setpoint


Active MW setpoint wind farm controller



WSAT


Power System Stability

Transient stability: the ability of the power system and individual generators to maintain synchronism after an operational disturbance. The system is within the **stability limit** when, after some given fault situations, it is able to return to an acceptable steady state situation.



WSAT (Wind Security Assessment Tool)


- Developed by EirGrid and external company to monitor the stability of the Irish power system with increasing levels of wind generation.
- Determines the voltage and transient stability of the system calculated for fault and no-fault conditions.



What affects Transient Stability?


Machine MW Output

- Within an operational range the higher the MW, the less stable a machine




Machine MVar Output

- Absorbing MVars BAD, Producing MVars GOOD
- To do with strength of the field between stator and rotor




Network Short-Circuit Level

- The higher the SCMVA, the more stable a machine
- SCMVA related to how many machines in vicinity and the state of the network how many outages




Machine Terminal Voltage

- Higher is better



Number of Synchronised Machines

- # of machines is better



WSAT Example (Loss of North – South Tie Line)

Largest Single Infeed 500MW

POR Required 75% of 500MW = 375MW

North – South flow = 300MW, (Limit 450MW – 20MW Offset)

NI POR = 130MW


ROI POR = 250MW

N-S Net Flow (Scheduled flow + Reserve)


$$T_{N-S} + \min(POR_{NI}, LSI_{IE} - 25\% POR_{IE}) \leq S_{MWR_{NI}}$$

$$300 + \min(130, 500 - 0.25 \times 250) \leq 430$$

$$430 = S_{MWR_{NI}} = \text{Max Flow}$$



WSAT Example (Loss of North – South Tie Line)



For loss of Tie Line

- System Separation
- Low Frequency in ROI, UFLS triggered.
- ROI system low inertia, only 5 big generators ON.
- Frequency slow to recover.
- High Frequency in NI.
- Interconnector runback activated and recovers NI frequency to within limits.

Preventative Control Measures

- Reduce the Tie Line flow by decreasing Generation in NI (reduce generation, reduce Moyle import or Constrain wind)
- Increase reserve provision in ROI, re-dispatch out of merit generation.
- Sync additional generation.

System Overview for Scheduling & Dispatch

