

# Weekly Operational Constraints Update

---

Applicable from 14 October 2019 to 20 October  
2019 (Week 42)

Rev 18 October 2019

---

## **Disclaimer**

*EirGrid plc, the Transmission System Operator (TSO) for Ireland, and SONI Limited, the TSO for Northern Ireland, support the provision of information to the marketplace by publishing operational data, processes, methodologies and reports. This information is key to a well-functioning market and as a transparency measure, assisting understanding of our decision making processes. EirGrid plc and SONI Limited make no warranties or representations of any kind with respect of this document, including, without limitation, its quality, accuracy and completeness. EirGrid plc and SONI Limited do not accept liability for any loss or damage arising from the use of this document or any reliance on the information it contains. Use of this document and the information it contains is at the user's sole risk.*



## Explanatory Notes

- The purpose of this Weekly Operational Constraints Update is to provide information on any forecasted significant network congestion or other issues that could potentially restrict dispatchable generation in a particular area or to flag if dispatchable generation is required in a particular area. These constraints are in addition to those presented in the monthly Operational Constraints Update document which should be read in conjunction with this document.
- In the analysis, a suite of N-1 contingencies are applied to the base case powerflow, and the resulting flows and voltages are compared against the Operational Security Standards. The N-1 contingencies include the tripping of each item of transmission plant and each generator transformer. Groups of generators / demand / wind etc. can be scaled up or down to determine a secure region of operation (known as transfer analysis or transaction analysis).
- The cases incorporate the latest generation and transmission outage information at the time of the study. This information is published on the EirGrid and SONI websites.
- Typically, from a dispatchable generation perspective the worst thermal constraints occur at peak system demand, and therefore only peak system demand scenarios are studied using transfer analysis. If required, other studies are performed, such as system demand valley where high voltages may be an issue.
- The wind levels in the various scenarios assume a flat profile across Ireland or Northern Ireland. We do not test Ireland wind levels above 1500 MW as, typically above these levels, constraints on dispatchable generation are not as binding due to the availability of the wind generation.
- The binding constraints on the flow on the North-South Tie Line from a thermal and voltage perspective tend to be due to thermal constraints on the Ireland side, save for specific Northern Ireland outages. This is why the Inter-Area Flow (North-South Tie Line Flow) Constraints Forecast below is only studied against Ireland wind generation.
- There may be other reasons, apart from voltage and thermal limits that lead to constraints, such as frequency, transient stability and adverse weather conditions. These are usually observed and dealt with close to real-time.
- Moyle Interconnector is limited to 80 MW export due to constraints on the Scotland side. National Grid Electricity Transmission plc performs daily studies to ascertain if this can be increased. Please note that the figures below in relation to interconnectors pertain to the Ireland/Northern Ireland side only.
- Should any of the study assumptions materially change during the week, due to a forced outage for example, we will endeavour to perform new studies and publish results on the next working day.

## Study Assumptions

### Generator and Transmission Outages

Generator and transmission plant outages as per published here:

[All-Island Generator Outages](#) – Under REMIT Publications

[Ireland Transmission Outages](#)

[Northern Ireland Transmission Outages](#)

### Demand

All studies are performed at Weekday Peak System Demand unless otherwise stated

Jurisdiction	Weekday Peak System Demand (MW)	Weekend Peak System Demand (MW)
Ireland	4250	3800
Northern Ireland	1350	1150

### Initial Interconnector and Tie Line Flows

	Flow (MW)
EWIC	At zero wind 250 MW Import (GB to IE) At 2000 MW wind 200 MW Export (IE to GB)
Moyle	N/A
North–South Tie Line Flow	0 MW Northern Ireland to Ireland / Ireland to Northern Ireland

## Constraints

The forecast constraints below are at Weekday Peak System Demand.

### South Generation Constraints Forecast (TCG Type: MW; Limit Type B) as per Operational Constraints Update

Ireland Wind Generation (MW)	Minimum South Generation (MW)	Maximum South Generation (MW)
0	0	670
1000	0	670
2000	0	670

### Cork Generation Constraints Forecast (TCG Type: MW; Limit Type B) as per Operational Constraints Update

Ireland Wind Generation (MW)	Minimum Cork Generation (MW)	Maximum Cork Generation (MW)
0	0	670
1000	0	670
2000	0	670

### Inter-Area Flow (North-South Tie Line Flow) Constraints Forecast

Ireland Wind Generation (MW)	Maximum Northern Ireland to Ireland flow (MW)	Maximum Ireland to Northern Ireland flow (MW)
0	390	390
1000	390	390
2000	390	390

## Interconnectors

Ireland Wind Generation (MW)	Maximum EWIC Import (MW)*	Maximum EWIC Export (MW)*	Maximum Moyle Import (MW)*	Maximum Moyle Export (MW)*
0	500	530	442	380
1000	500	530	442	380
2000	500	530	442	380

\* Values pertain to the Ireland/Northern Ireland side of the interconnectors only

## Coolkeeragh C30 Running

Northern Ireland Wind Generation (MW)	Northern Ireland Demand (MW) above which C30 must be running with GT8 off	Northern Ireland Demand (MW) above which C30 must be running with GT8 operating as a synchronous compensator	Northern Ireland Demand (MW) above which C30 must be running with GT8 operating as a generator
0	1550	1608	Not required
450	Not required	Not required	Not required
900	Not required	Not required	Not required

## Other Constraints/Notes/Risks

Jurisdiction	Constraint/Note	Reason
Ireland / Northern Ireland	System Operator trading on Interconnectors will only be employed for system security reasons.	Due to the transition to the new market arrangements we are setting a high bar to trade.  We are currently trialling the trading arrangements and we will provide an update when trading for priority dispatch reasons is phased in.
Ireland	Moneypoint 2 (MP2) is currently unable to export.	Transmission system outage.

Ireland	There may be a requirement for an additional Dublin unit for load flow reasons during low load and high EWIC exports.	Load Flow
Ireland	Aghada Unit (AT4) is currently unable to export.	Transmission system outage.
Ireland	Aghada Units AT1 and AT2 are constrained off during week days (Mon – Fri) until 17 October. The constraint on AT1 and AT2 may be lifted at short notice (<1 day) if additional generation or reserve is required.	Transmission works in Aghada 220kV station.
Ireland	There may be a requirement for a large Tarbert unit (TB3 or TB4) during periods of low wind in the South West.	Voltage Support to facilitate commissioning of new transmission equipment.