Withdrawal Notification Mod\_08\_21 Removing the 10MW limit for some Demand Sites to enable Demand Sites that include, or are, an Individual Battery Storage Unit > 10MW to participate as part of a Demand Side Unit (DSU)



## 7 September 2021Withdrawal Notification

Mod\_08\_21 Removing the 10MW limit for some Demand Sites to enable Demand Sites that include, or are, an individual Battery Storage Unit > 10MW to participate as part of a Demand Side Unit (DSU)

## 1 MODIFICATIONS COMMITTEE MEETING 106 MINUTES

The Proposer gave an update on this Modification noting conversations with Flextech and SEMO. It was advised that there was a need for a direct communication between the control centre and dispatchable sites greater than 10MW. Currently a battery above 10MWs within a DSU may not be able to get that visibility and this is outside the remit of the Trading and Settlement Code. As a result it was agreed that this Modification Proposal would be withdrawn.

## **Decision**

The Proposal was withdrawn.